



WARNING
Analog output lines
must not be connected
to any kind of voltage
or current source,
serious damage will
result.

Notes:

1. Power Cord - Provided w/ wall plug connector and 8 Ft. 3 conductor wire.
2. Audible and Visual Alarm (Optional) factory wired. Remote Audible and Visual Alarms must be 120VAC and connected to terminal Strip on Lower Circuit Board.
3. Sensor Cable between Haloguard® Controller and CMOS Sensor - Maximum Length 300FT. Use 3 conductor 18 or 20ga. w/ foil shield.
4. Analog Outputs (Optional) are either 0 - 5VDC, 0 - 10VDC, or 4 - 20mA.